

Wiggin and Dana LLP  
One Century Tower  
P.O. Box 1832  
New Haven, Connecticut  
06508-1832  
www.wiggin.com

Bruce L. McDermott  
203.498.4340  
203.782.2889 fax  
bmcdermott@wiggin.com

WIGGIN AND DANA  
*Counsellors at Law*

VIA MESSENGER

January 6, 2006


Pamela B. Katz  
Chairman  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051

Re: Life-Cycle 2006 - The Connecticut Siting Council Investigation  
into the Life-Cycle Costs of Electric Transmission Lines

Dear Chairman Katz:

I enclose an original and twenty copies of the Pre-file Testimony of The United Illuminating Company. If you have any questions about this filing, please do not hesitate to contact me.

Very truly yours,



Bruce L. McDermott

cc: Service List

Enclosures

\\10705\\276\\571026.1

STATE OF CONNECTICUT

SITING COUNCIL

Re: The Connecticut Siting Council Investigation ) Life-Cycle 2006  
into the Life-Cycle Costs of Electric )  
Transmission Lines ) January 6, 2006

**DIRECT TESTIMONY OF THE UNITED ILLUMINATING COMPANY**

1

2 **Executive Summary**

3 Q. Mr. Reed, would you please identify yourself and the other member of the  
4 panel from The United Illuminating Company (the "Company" or "UI") who will  
5 respond to cross examination?

6 A. I am Richard J. Reed. My business address is 801 Bridgeport Avenue,  
7 Shelton, CT 06484. I am the Vice President of Electric Systems at UI. I joined UI in  
8 1970 and have held various leadership positions in the Company, including Director of  
9 Customer Service and my current position, Vice President - Electric System. With me is  
10 John Prete who, since October 2002, has been UI's Project Director for the Middletown  
11 to Norwalk Project. John is responsible for the schedule, scope and costs of the project  
12 for UI and in concert with Northeast Utilities.

13 Q. What is the purpose of your testimony?

14 A. The purpose of this testimony is to assist the Council and its consultant,  
15 KEMA, in revising or updating the Council's "Life-Cycle Cost Studies for Overhead and  
16 Underground Transmission Lines," first prepared by ACRES International in March,

1 1996 (the “1996 Report”) and updated by ACRES in 2001 (the “2001 Report”) and to  
2 identify the issues that the Council should investigate as part of the update. Specifically,  
3 this testimony will provide the Council with information that will assist the Council in  
4 investigating the comparative life-cycle costs of overhead and underground transmission  
5 lines, as required by Conn. Gen. Stats. §§ 16-50r(b) and (c), by discussing new  
6 developments in the transmission line field during the last five years. This testimony  
7 does not, however, quantify the specific costs associated with the construction of electric  
8 transmission lines since the Company believes that the construction costs are directly  
9 related to the location of the line.

10 UI wishes to thank the Council for the opportunity to participate in this five-year  
11 review. At the outset, UI notes that the 1996 Report and the 2001 Report were based on  
12 115-kV transmission only. The Company concurs with the Council’s recommendation  
13 that the 2006 report include 345-kV transmission as well.

14

15 **Updated Information on First Costs**

16 Q. Are there particular issues you think the Council should focus on as part of its  
17 effort to update the 2001 Report?

18 A. Yes. UI has identified areas in which the cost categories considered in the  
19 2001 Report should be updated. Generally, costs have increased since 2001 for both  
20 overhead and underground transmission lines. For example, since the 2001 review of  
21 lifecycle costs, there have been significant cost increases for the labor and commodities  
22 necessary to construct both overhead and underground transmission lines. The level of  
23 cost increases has been exacerbated over the past year as a result of recent natural

1 disasters, which have impacted the rising cost of fuel, high demand for steel and copper,  
2 labor, material and manufacturing shortages. These cost increases warrant consideration  
3 in this update of the study.

4 Q. Since 2001, has there been an increase in the costs of permitting a  
5 transmission line?

6 A. In the 1996 Acres study, permitting costs for 115-kV construction were  
7 estimated to be \$100,000 per project. Permitting costs have increased since 1996 for all  
8 projects, and can be expected to increase further as a result of the new role of the  
9 Connecticut Energy Advisory Board and requests for proposal in the siting process. The  
10 cost of permitting for 345 kV projects is increased further by the costs of complying with  
11 the requirements” of Public Act 04-246. While the specific permitting cost will vary by  
12 project, the Company looks forward to the opportunity to participate with the Council’s  
13 consultant in preparing estimates for this component of the lifecycle cost study.

14 Q. What impact on cost results from construction of an overhead vs. an  
15 underground transmission line?

16 A. Overhead and underground project alternatives will not follow precisely  
17 the same route, will have different areas of concern, and must comply with different  
18 statutory requirements. All of these factors will affect the actual cost comparison of  
19 overhead and underground alternatives for a project, in addition to generic “per mile”  
20 lifecycle cost comparisons. For example, the provisions of Public Act 04-246 require a  
21 presumption that 345-kV facilities will be constructed underground if adjacent to  
22 facilities such as schools, residential areas etc., unless burying the facility is  
23 technologically infeasible. This requirement will result in complexity (the need to

1 “porpoise,” for example) and cost (in the porpoising example, the need to acquire  
2 property and build two transition stations) that is not necessarily reflected in a simple  
3 comparison of 5 miles of overhead construction versus a similar underground alternative.  
4 The development of lifecycle costs for 345 kV overhead and underground alternatives  
5 should include a robust treatment of these costs.

6 Q. Would you please describe your experience with XLPE cable?

7 A. The Company will be completing its first installation of XLPE  
8 underground cable operating at 345 kV over the next four years. The 345 kV loop in  
9 Connecticut will represent the first installation of field spliced 345 kV XLPE  
10 underground in the continental United States. In its response to Q-CSC- 4 the Company,  
11 in conjunction with CL&P, provided our most recent estimate for this type of  
12 construction. Over the next four years, the Company actually will be incurring the  
13 installation costs associated with this technology. Areas for consideration in the 2006  
14 update should include the costs associated with Department of Transportation  
15 requirements for underground construction on or along state roadways and the costs  
16 associated with the handling, testing and disposal of materials excavated from roads. The  
17 Company looks forward to working with the Council in leveraging our experience in the  
18 Middletown to Norwalk Project in the Council’s work on lifecycle costs.

19

20 **Update on Developments Discussed in 2001 Report**

21 Q. Does the Company have any updated information concerning the topics  
22 discussed in the 2001 Report?

1           A.     Yes. There are several technological advances and other developments  
2 that were identified in the 2001 Report as potentially affecting costs for overhead or  
3 underground transmission construction/maintenance for the period 2001 and beyond  
4 which the Council should consider in updating the 2001 Report:

5           Line Ratings: On page 10 of the 2001 Report, *“recent technological advances*  
6 *and technologies that are allowing utilities to increase the flow of power across their*  
7 *transmission lines while still maintaining or even improving their reliability”* was  
8 discussed. In 2004, the Company implemented the combination of a forced-air cooling  
9 system and a dynamic thermal monitoring system on the 1710 and 1730 115 kV  
10 underground circuits, which are a critical part of the transmission corridor for transferring  
11 power, generated by merchant plants connected to the Pequonnock Substation in  
12 Bridgeport, to loads in southwestern Connecticut (“SWCT”). Any reduction in the  
13 current-carrying capability of these underground circuits as a result of not implementing  
14 the forced air cooling and the dynamic thermal monitoring system on the 1710/1730  
15 circuits would have resulted in considerable reliability risks and additional congestion  
16 costs for consumers. In addition, this technological advancement of applying a dynamic  
17 thermal monitoring system was at least three times the capital cost savings of the  
18 traditional method of increasing the circuit capacity by reconductoring the underwater  
19 and underground sections of circuits 1710/1730 with High Pressure Gas Filled (“HPGF”)  
20 115- kV cable.

21           NESC: Page 6 of the 2001 Report lists several updates to the National Electric  
22 Safety Code (“NESC”) that were being considered at the time. In 2002 an update to the  
23 NESC was released that increased the requirements for transmission line construction

1 relevant to wind and ice loading. The Company's construction standards at the time were  
2 sufficient to accommodate the additional loading requirements and did not require  
3 update. These changes therefore have no impact on the Company's transmission  
4 lifecycle costs.

5 Wood Pole Preservatives: Page 7 of the 2001 Report discussed the possibility  
6 that Penta, the most commonly used pole preservative (which UI uses for both  
7 transmission and distribution poles) might be banned by the Environmental Protection  
8 Agency ("EPA"). The EPA did not ban this substance, and the Company continues to  
9 use it.

10 Transmission Planning Requirements: UI does not expect any ISO-NE planning  
11 and operating standards for design and operations of transmission facilities to impact  
12 transmission line life cycle costs in the near term.

13 On August 8, 2005 the Energy Policy Act of 2005 was signed into law. This Act  
14 will give the Federal Energy Regulatory Commission ("FERC") new responsibilities in  
15 overseeing the reliability of the nation's electric transmission grid. On September 1,  
16 2005, FERC issued a notice of proposed rulemaking on *Rules Concerning Certification*  
17 *of the Electric Reliability Organization; and Procedures for the Establishment, Approval*  
18 *and Enforcement of Reliability Standards*. Under the Act a new national Electric  
19 Reliability Organization would be responsible for developing national reliability  
20 standards subject to FERC approval. The outcome of this Act may impact transmission  
21 lifecycle costs in the future.

22 Life Expectancy: A transmission line life expectancy of 35 - 40 years was  
23 assumed in the 2001 Report. The Company believes that there is no basis to change that

1 assumption. Because 90% of the lifecycle cost occurs in the first 22 years, any cost  
2 beyond 35 years contributes very little to the lifecycle cost.

3 EMF: Methods of calculating electric and magnetic fields are well-established,  
4 with well-defined protocols. The Company is aware of no new methods for the  
5 calculation of electric and magnetic fields for transmission lines that have developed  
6 since 2001.

7 Q. Are there other changes of which the Council should be aware?

8 A. Yes. The Council should be aware of the following technological  
9 advancements:

10 HDD: Horizontal Directional Drilling: Although the Company has had experience  
11 with directional drilling in distribution applications, the Middletown to Norwalk Project  
12 will be UI's first implementation of horizontal directional drilling in a transmission  
13 application. The Company will have actual cost information as it proceeds with this  
14 technology.

15 Polymer Insulators: Since 1987, UI has had experience with polymer insulators on  
16 a short line. In this application, the polymer insulators have performed well to date. In  
17 2003 a truck fire occurred on I-95 in close proximity to this line. There was a concern  
18 that the insulators directly over the fire were damaged, so they were removed from  
19 service and a forensic analysis was performed. The analysis revealed that the insulators  
20 were in good working order and showed no sign of degradation prior to the fire.  
21 However, because porcelain insulators have similar cost and the Company has not had a  
22 problem with porcelain insulators, UI does not see a basis for polymer insulators to  
23 replace porcelain as the Company's standard.



1       High Temperature Low Sag Conductors: The Company continues to follow  
2 industry developments with high temperature low sag conductors. The Company  
3 recognizes this technology as an alternative for capacity upgrades on existing lines where  
4 there are lifecycle cost savings to be realized through the elimination of structural  
5 upgrades. These lifecycle cost savings would need to be weighed against the  
6 uncertainties around the long term reliability of these new conductors and their associated  
7 hardware.

8       High Voltage Direct Current ("HVDC"): The Company continues to recognize  
9 HVDC as a viable technology for long distance power transfers, in both overhead and  
10 underground applications, if the HVDC proposal meets the system reliability and  
11 operational needs cost-effectively.

12       Q.     Does this conclude your testimony?

13       A.     Yes.

14

15

16       \\10705\1227\570816.1

17